

# 連續自動監測紀錄月報表

中華民國107年10月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	8.72	82.58	2.01	10.12	3.88	79455.47	17.76	7.89	1.62	149.36	12.16
02	8.81	85.14	3.93	10.20	3.84	79269.45	17.78	8.51	1.60	149.64	12.25
03	9.49	88.17	4.63	10.39	3.78	79447.26	17.42	10.32	1.57	149.84	12.43
04	9.24	88.67	4.91	10.31	3.72	78795.02	17.81	11.09	1.55	149.46	12.28
05	9.28	88.32	3.24	10.26	3.75	78359.99	18.32	9.88	1.56	150.75	12.27
06	9.60	90.74	2.62	10.32	3.75	78595.38	17.72	10.58	1.56	149.66	12.25
07	9.88	87.90	2.84	10.30	3.70	78465.78	17.42	11.11	1.54	149.23	12.15
08	9.08	86.42	2.51	10.14	3.66	78410.77	18.28	7.84	1.52	149.36	12.10
09	8.18	92.87	1.96	10.38	3.73	78788.22	18.43	6.74	1.55	151.73	12.52
10	9.04	89.93	4.34	10.34	3.75	79091.27	18.34	10.14	1.56	150.41	12.48
11	8.92	86.52	3.43	10.24	3.72	79033.82	18.09	9.67	1.55	149.30	12.30
12	9.65	93.40	4.70	10.49	3.76	79310.77	18.15	10.04	1.57	149.80	12.64
13	9.46	91.67	5.47	10.36	3.76	79493.22	18.16	10.09	1.57	149.81	12.51
14	8.71	91.52	1.81	10.24	3.78	79751.74	18.58	8.59	1.57	150.15	12.48
15	8.80	90.77	2.87	10.41	3.78	79424.41	18.26	8.26	1.57	150.70	12.62
16	9.45	94.40	3.31	10.52	3.78	79036.09	18.02	10.06	1.58	150.65	12.64
17	10.46	93.58	3.71	10.53	3.68	77982.01	17.44	11.81	1.53	149.60	12.36
18	9.70	92.51	3.00	10.39	3.66	78741.08	17.70	10.50	1.52	149.77	12.36
19	9.73	95.55	2.51	10.50	3.67	79046.96	17.77	12.42	1.53	149.99	12.55
20	9.94	93.12	4.33	10.42	3.63	78734.82	17.42	12.53	1.51	149.73	12.35
21	10.10	89.92	3.07	10.21	3.69	79339.67	17.87	9.83	1.54	149.68	12.28
22	8.77	86.63	3.46	10.13	3.74	79111.66	17.82	7.58	1.56	149.26	12.12
23	9.08	88.81	5.65	10.39	3.76	77861.86	17.28	7.47	1.56	149.07	12.14
24	12.42	90.74	7.64	10.45	3.73	79289.34	17.17	12.06	1.55	150.07	12.46
25	11.89	89.72	4.13	10.40	3.72	77618.23	17.32	9.23	1.55	149.40	12.13
26	10.65	88.22	6.01	10.32	3.66	77111.17	17.34	12.96	1.52	148.92	11.95
27	10.21	90.75	6.02	10.37	3.69	77938.52	16.69	12.68	1.54	148.81	12.04
28	11.46	92.67	7.08	10.49	3.66	78845.11	16.18	12.70	1.53	149.96	12.27
29	9.53	90.68	2.67	10.36	3.66	79777.84	16.80	10.26	1.52	152.70	12.43
30	8.99	88.39	3.31	10.30	3.67	79650.91	16.78	10.97	1.53	158.10	12.50
31	10.89	91.49	7.16	10.54	3.61	78511.76	16.39	12.13	1.50	156.17	12.51
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	9.68	90.06	4.01	10.35	3.72	78848.05	17.63	10.19	1.55	150.36	12.34
最大值	12.42	95.55	7.64	10.54	3.88	79777.84	18.58	12.96	1.62	158.10	12.64
發生日期											
最小值	8.18	82.58	1.81	10.12	3.61	77111.17	16.18	6.74	1.50	148.81	11.95
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國107年10月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	12.31	77.94	13.95	14.47	3.66	75275.40	11.77	2.11	1.52	111.19	16.27
02	12.93	81.16	21.93	14.48	3.68	74823.32	11.89	2.55	1.53	110.43	16.22
03	13.15	79.94	16.11	14.55	3.69	73883.67	11.94	2.78	1.54	110.31	16.17
04	13.38	79.62	11.93	14.65	3.81	72509.34	12.56	3.63	1.59	109.89	16.22
05	12.51	78.82	16.43	14.64	3.83	71699.33	13.02	1.66	1.60	110.87	16.13
06	13.04	75.78	14.19	14.62	3.76	72664.62	12.48	2.20	1.57	111.72	16.19
07	14.12	78.82	19.01	14.74	3.70	71623.57	11.96	3.50	1.54	110.39	16.16
08	13.09	80.34	11.33	14.67	3.62	71665.58	12.57	2.72	1.51	110.60	16.10
09	12.37	81.17	18.97	14.71	3.70	69569.12	12.62	1.24	1.54	110.28	15.78
10	13.34	78.29	14.60	14.72	3.67	71313.37	12.57	2.46	1.53	110.07	16.14
11	13.43	75.59	23.70	14.69	3.60	72133.77	12.20	2.00	1.50	108.93	16.13
12	14.10	74.02	17.38	14.68	3.61	72612.09	12.38	2.26	1.50	108.25	16.20
13	12.53	76.64	14.76	14.65	3.58	73122.81	12.51	1.74	1.49	108.23	16.27
14	12.56	76.61	15.98	14.55	3.58	73554.65	12.85	1.25	1.49	109.26	16.20
15	12.49	73.52	13.79	14.55	3.55	72849.53	12.67	0.99	1.48	109.33	16.16
16	13.87	79.96	22.57	14.75	3.60	71289.47	12.27	1.28	1.50	109.31	16.10
17	13.85	79.71	17.09	14.80	3.54	71613.04	11.76	2.56	1.47	108.07	16.17
18	13.30	82.06	16.44	14.75	3.51	72112.62	11.84	2.44	1.46	108.46	16.20
19	13.32	78.87	14.77	14.73	3.49	72645.96	11.73	2.44	1.45	108.14	16.20
20	14.35	78.65	12.74	14.74	3.44	72706.58	11.31	4.03	1.43	108.46	16.18
21	13.75	76.28	20.63	14.63	3.48	73071.55	11.83	3.35	1.45	108.79	16.10
22	12.90	76.49	21.08	14.72	3.52	71477.30	11.81	1.33	1.47	108.51	15.96
23	14.03	78.68	26.97	14.79	3.55	71353.26	11.66	2.20	1.48	108.45	16.09
24	15.57	76.94	32.77	14.74	3.57	71921.28	11.36	13.87	1.49	108.72	16.04
25	13.63	78.30	24.62	14.80	3.51	71218.94	11.40	9.75	1.46	109.24	16.08
26	14.89	80.62	23.02	14.78	3.45	71419.54	11.47	15.57	1.44	108.89	16.03
27	15.03	78.64	20.08	14.79	3.47	72707.27	10.55	16.31	1.45	107.77	16.14
28	14.92	76.22	19.10	14.79	3.47	72658.39	10.46	15.98	1.45	106.02	16.07
29	13.32	72.22	14.66	14.65	3.49	73888.88	10.99	8.79	1.46	106.04	16.04
30	13.45	75.95	14.67	14.72	3.51	72518.31	11.33	9.20	1.46	107.69	16.09
31	14.04	78.31	22.15	14.96	3.46	70454.34	10.78	10.67	1.44	106.69	16.09
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	13.53	77.94	18.30	14.69	3.58	72334.09	11.89	4.93	1.49	109.00	16.13
最大值	15.57	82.06	32.77	14.96	3.83	75275.40	13.02	16.31	1.60	111.72	16.27
發生日期											
最小值	12.31	72.22	11.33	14.47	3.44	69569.12	10.46	0.99	1.43	106.02	15.78
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管