

連續自動監測紀錄月報表

中華民國108年1月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO ₂	NO _x	CO	O ₂	DUST	MASS	H ₂ O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	8.12	80.30	1.76	10.04	2.01	81628.69	18.53	9.01	0.84	147.64	12.47
02	8.08	77.60	2.13	9.88	2.01	82154.04	18.79	7.87	0.84	147.68	12.40
03	8.45	77.40	4.43	9.74	2.03	82990.33	18.81	9.78	0.84	148.07	12.38
04	8.11	78.97	3.51	9.91	2.04	83406.52	18.45	11.45	0.85	149.69	12.64
05	8.44	80.27	4.57	9.96	2.03	81673.42	17.96	11.27	0.85	148.52	12.32
06	8.31	82.40	2.99	9.91	1.94	82063.25	18.30	9.45	0.81	148.11	12.36
07	7.90	81.20	2.88	9.90	1.98	82411.45	18.15	9.75	0.82	148.76	12.41
08	8.32	88.38	2.26	10.12	1.97	82204.94	18.49	9.92	0.82	149.28	12.69
09	8.62	79.94	6.37	9.97	1.93	82062.60	18.48	10.95	0.80	148.41	12.46
10	9.77	79.07	5.96	9.89	1.97	82076.65	18.73	10.32	0.82	148.80	12.43
11	9.25	86.90	3.29	10.04	1.97	83223.14	18.06	11.18	0.82	148.78	12.67
12	8.73	81.31	3.85	9.89	1.96	84029.27	18.73	11.64	0.81	148.98	12.73
13	9.07	83.68	4.95	10.08	1.91	83098.44	18.39	12.26	0.79	148.90	12.75
14	7.66	78.84	6.32	9.96	1.84	81134.25	18.09	11.86	0.77	147.84	12.24
15	9.75	77.09	6.12	9.72	1.85	81416.20	18.49	10.85	0.77	148.24	12.09
16	8.87	83.23	5.04	9.91	1.80	82476.27	18.18	10.67	0.75	147.94	12.40
17	8.02	77.80	4.27	9.96	1.74	82951.26	18.52	9.78	0.72	148.19	12.59
18	8.58	77.60	4.68	9.88	1.82	83846.87	18.28	11.41	0.76	148.27	12.60
19	9.40	79.76	6.20	9.93	1.86	83273.00	18.02	13.12	0.78	148.41	12.53
20	9.18	77.17	5.76	9.91	1.87	83045.38	18.36	12.70	0.78	148.26	12.52
21	8.33	80.60	4.71	10.09	1.82	82345.79	17.80	10.85	0.76	147.61	12.53
22	8.66	76.71	2.64	9.89	1.83	83122.11	17.95	10.94	0.76	147.19	12.42
23	8.48	76.48	4.52	9.89	1.86	84196.52	18.19	10.75	0.77	147.69	12.63
24	8.43	76.63	5.93	9.98	1.99	82411.84	18.13	11.52	0.83	147.95	12.46
25	9.48	81.94	5.02	10.22	2.00	79962.03	17.98	12.49	0.84	148.04	12.34
26	9.56	81.11	4.76	10.21	1.99	80319.19	17.51	12.85	0.83	147.19	12.29
27	9.40	81.84	4.00	10.22	1.96	80698.27	17.25	12.68	0.82	147.12	12.32
28	9.12	83.55	6.44	10.39	1.97	78632.63	16.77	12.99	0.82	147.18	12.13
29	9.27	79.73	5.19	10.39	1.99	78675.11	17.34	13.53	0.83	147.99	12.24
30	10.36	74.75	11.30	10.24	1.95	78110.73	17.15	13.69	0.81	147.09	11.93
31	9.09	71.99	13.41	10.16	1.93	78050.17	17.16	13.16	0.80	145.71	11.80
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	8.80	79.81	5.01	10.01	1.93	81860.98	18.10	11.31	0.80	148.05	12.41
最大值	10.36	88.38	13.41	10.39	2.04	84196.52	18.81	13.69	0.85	149.69	12.75
發生日期											
最小值	7.66	71.99	1.76	9.72	1.74	78050.17	16.77	7.87	0.72	145.71	11.80
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管

連續自動監測紀錄月報表

中華民國108年1月31日

項目 日期	管制編號			F0501686		煙道排放口編		P002			
	SO ₂ 二氧化硫	NO _x 氮氧化物	CO 一氧化碳	O ₂ 氧氣	DUST 粉塵濃度	MASS 排放流率	H ₂ O 水份	HCL 鹽酸	OPAC 不透光率	TEMP 溫度	VEL 流速
	ppm	ppm	ppm	%	mg/m ³	Nm ³ /hr	%	ppm	%	°C	m/s
01	14.17	79.93	14.86	14.73	3.53	69260.44	11.36	4.72	1.47	108.93	15.42
02	14.47	78.58	17.83	14.71	3.53	69254.54	11.36	5.52	1.47	109.58	15.39
03	14.68	78.06	22.84	14.70	3.48	69358.23	11.32	5.99	1.45	110.02	15.41
04	15.34	80.76	19.15	14.83	3.44	67448.75	11.10	8.77	1.43	111.59	15.32
05	15.30	84.56	11.68	14.87	3.54	67346.67	11.02	8.85	1.47	110.41	15.35
06	14.83	83.43	7.98	14.87	3.57	67444.58	11.13	6.21	1.49	109.61	15.36
07	15.02	81.42	14.92	14.86	3.49	67237.24	10.87	7.09	1.45	110.73	15.28
08	15.04	76.74	18.46	14.81	3.46	67587.82	11.41	6.97	1.44	110.59	15.31
09	15.74	80.75	16.10	14.80	3.41	68229.54	11.02	10.92	1.42	110.34	15.36
10	16.92	75.82	15.66	14.75	3.48	67442.03	11.46	10.82	1.45	111.51	15.19
11	15.41	80.08	15.70	14.84	3.39	66216.16	11.49	10.38	1.41	111.42	15.14
12	16.10	81.26	17.74	14.82	3.32	67057.27	11.17	12.21	1.38	110.56	15.18
13	17.00	82.71	14.39	14.88	3.29	66672.38	10.93	15.50	1.37	110.15	15.20
14	15.66	85.53	12.49	14.82	3.24	67666.18	10.79	13.47	1.35	110.99	15.27
15	13.37	76.47	17.68	14.95	3.26	67164.45	11.04	12.03	1.36	111.27	15.53
16	15.98	79.85	23.03	14.82	3.19	71521.28	10.89	14.36	1.33	109.61	16.10
17	15.23	82.08	11.98	14.83	3.16	71340.21	10.82	11.87	1.32	108.78	16.02
18	16.05	80.27	16.15	14.71	3.12	72734.72	10.67	15.50	1.30	109.84	16.07
19	16.22	81.81	15.46	14.88	3.14	70199.61	10.67	14.34	1.31	109.67	15.93
20	16.63	82.71	16.53	14.79	3.17	71089.27	10.91	17.31	1.32	109.84	15.94
21	15.40	76.94	13.03	14.70	3.09	72234.60	10.63	14.48	1.29	108.61	15.87
22	14.93	80.28	11.32	14.82	3.15	70821.14	10.66	9.08	1.31	107.72	15.82
23	15.18	74.42	17.90	14.66	3.13	72134.78	10.69	11.01	1.30	108.31	15.74
24	15.25	80.73	13.82	14.83	3.45	68522.70	10.94	9.50	1.44	110.34	15.51
25	17.10	82.76	18.43	15.05	3.38	65207.81	10.77	15.91	1.41	110.31	15.25
26	16.35	78.99	27.06	14.94	3.29	67135.11	10.40	18.51	1.37	108.81	15.30
27	16.28	79.94	18.28	15.01	3.36	66485.27	10.25	16.03	1.40	108.81	15.32
28	16.53	78.98	24.43	15.14	3.47	64813.97	10.11	16.98	1.44	109.34	15.26
29	16.91	77.36	13.53	15.07	3.49	65408.14	10.40	16.87	1.45	110.72	15.31
30	17.51	74.90	26.35	15.14	3.39	64606.78	10.33	20.12	1.41	110.63	15.28
31	17.12	78.68	26.70	15.23	3.29	63944.49	10.02	16.46	1.37	109.54	15.27
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	15.73	79.90	17.14	14.87	3.35	68180.20	10.86	12.19	1.39	109.95	15.47
最大值	17.51	85.53	27.06	15.23	3.57	72734.72	11.49	20.12	1.49	111.59	16.10
發生日期											
最小值	13.37	74.42	7.98	14.66	3.09	63944.49	10.02	4.72	1.29	107.72	15.14
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管