

# 連續自動監測紀錄月報表

中華民國107年12月31日

				管制編號		F0501686		煙道排放口編		P001	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	11.25	93.86	12.25	10.10	1.82	80084.58	15.43	11.84	0.76	147.49	11.83
02	10.36	89.37	5.56	10.15	1.91	77702.45	16.43	10.07	0.79	147.55	11.68
03	9.32	81.82	3.95	9.80	1.89	78698.00	17.32	8.74	0.79	147.35	11.58
04	8.97	86.09	6.97	10.06	1.91	78885.24	17.82	8.61	0.80	148.39	11.99
05	9.54	84.61	5.96	10.25	1.91	79039.17	17.46	9.56	0.80	147.97	12.16
06	9.26	88.70	6.01	10.25	1.93	79164.91	17.27	10.82	0.80	148.45	12.17
07	9.01	92.13	2.43	10.48	1.83	78807.66	17.50	8.79	0.76	147.93	12.39
08	10.14	90.59	4.47	10.41	1.84	78804.23	16.91	10.66	0.77	147.58	12.21
09	9.05	86.79	1.97	10.09	1.83	79464.01	18.08	8.60	0.76	146.87	12.09
10	8.35	86.57	2.75	10.13	1.85	78308.06	17.70	6.73	0.77	147.21	11.92
11	8.93	87.23	3.14	10.21	1.80	78243.69	17.77	7.38	0.75	147.44	12.02
12	9.47	88.49	7.85	10.39	1.72	78152.09	16.48	9.17	0.72	146.40	12.01
13	9.05	83.82	3.57	10.02	1.82	78349.26	17.28	9.18	0.76	146.41	11.73
14	9.57	85.44	4.12	10.00	1.86	79179.95	17.94	9.27	0.77	147.58	11.96
15	10.08	80.97	6.95	9.77	1.88	80454.96	17.93	10.60	0.79	147.70	11.90
16	9.80	77.68	7.45	9.82	2.03	79812.12	17.73	10.85	0.84	147.80	11.83
17	8.41	76.05	4.01	9.80	2.01	81447.58	18.32	8.11	0.84	147.31	12.13
18	9.87	80.66	4.24	9.98	1.97	81377.21	17.34	9.88	0.82	147.49	12.17
19	9.30	79.45	5.83	9.89	2.01	81096.53	17.94	10.37	0.84	148.65	12.16
20	8.93	76.13	6.14	9.80	1.98	80173.82	18.04	9.37	0.83	147.30	11.90
21	9.29	75.82	6.87	9.86	1.98	79460.61	18.14	11.42	0.83	147.82	11.89
22	9.68	72.37	9.92	9.66	2.01	79900.42	18.59	11.76	0.84	147.95	11.81
23	9.34	73.35	9.05	9.64	2.04	80032.83	18.36	11.07	0.85	147.53	11.76
24	8.11	71.83	6.89	9.77	2.04	80518.67	18.45	7.01	0.85	146.98	11.97
25	8.65	70.98	5.62	9.52	2.04	80060.67	19.26	8.08	0.85	147.29	11.75
26	9.50	73.94	7.80	9.84	1.89	79248.17	18.50	10.55	0.79	147.27	11.87
27	8.66	74.37	6.36	10.02	1.89	77706.16	17.96	10.55	0.79	146.14	11.72
28	7.86	81.22	2.94	10.40	1.95	80153.62	17.88	12.11	0.81	146.95	12.53
29	8.10	84.13	2.61	10.37	1.90	81379.72	17.25	11.34	0.79	146.18	12.57
30	8.31	81.86	1.83	10.06	2.00	81890.25	17.88	11.44	0.83	146.81	12.40
31	8.10	82.22	2.89	10.08	1.99	81562.40	18.18	10.95	0.83	147.45	12.44
監測日數	31	31	31	31	31	31	31	31	31	31	31
平均值	9.17	81.89	5.43	10.02	1.92	79650.29	17.71	9.83	0.80	147.39	12.02
最大值	11.25	93.86	12.25	10.48	2.04	81890.25	19.26	12.11	0.85	148.65	12.57
發生日期											
最小值	7.86	70.98	1.83	9.52	1.72	77702.45	15.43	6.73	0.72	146.14	11.58
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----

備註

廠長

維修組長

操作組長

值班主管

# 連續自動監測紀錄月報表

中華民國107年12月31日

				管制編號		F0501686		煙道排放口編		P002	
項目 日期	SO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	DUST	MASS	H <sub>2</sub> O	HCL	OPAC	TEMP	VEL
	二氧化硫	氮氧化物	一氧化碳	氧氣	粉塵濃度	排放流率	水份	鹽酸	不透光率	溫度	流速
	ppm	ppm	ppm	%	mg/m <sup>3</sup>	Nm <sup>3</sup> /hr	%	ppm	%	°C	m/s
01	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機	停機
02	16.78	103.39	30.65	15.19	2.92	65513.84	9.79	14.62	1.22	111.16	15.57
03	15.55	96.25	15.05	15.07	2.95	66601.48	10.97	8.86	1.23	110.47	15.68
04	17.74	98.94	14.49	15.22	3.00	65613.45	10.55	12.38	1.25	111.11	15.81
05	17.02	95.01	21.03	15.27	3.05	65168.28	10.38	13.21	1.27	111.98	15.84
06	16.91	90.82	19.64	15.11	3.11	65954.57	10.71	14.66	1.29	112.75	15.66
07	16.32	97.18	12.64	15.11	3.15	66329.38	10.69	11.77	1.31	111.20	15.72
08	17.53	95.16	13.64	15.22	3.20	65654.01	10.14	13.58	1.33	110.48	15.72
09	15.88	89.00	11.64	15.00	3.26	67460.79	10.99	10.16	1.36	110.38	15.68
10	15.72	90.31	16.36	15.08	3.31	65777.49	10.97	7.03	1.38	111.16	15.55
11	16.13	94.50	11.06	15.10	3.27	65565.59	11.01	6.64	1.36	110.88	15.53
12	16.24	91.13	11.04	15.13	3.26	66473.22	10.00	9.42	1.36	108.70	15.58
13	15.50	90.17	10.19	15.01	3.32	67424.10	10.34	9.48	1.38	109.29	15.54
14	15.97	90.89	13.04	15.02	3.37	66893.86	10.65	8.65	1.40	109.50	15.52
15	15.63	86.77	7.97	14.92	3.37	67571.79	10.97	8.86	1.40	110.40	15.50
16	16.41	87.13	14.25	15.09	3.43	65428.93	10.62	9.93	1.43	110.21	15.40
17	15.25	78.69	17.56	14.88	3.39	68243.70	10.87	7.47	1.41	108.20	15.44
18	15.17	80.39	19.49	14.81	3.40	69258.78	10.51	6.77	1.42	108.87	15.47
19	15.89	83.04	12.18	14.93	3.41	67275.38	10.55	10.15	1.42	110.27	15.40
20	15.91	83.32	19.11	15.03	3.42	65850.44	10.68	8.66	1.42	109.70	15.31
21	16.30	83.82	15.91	15.01	3.39	65785.59	10.97	11.29	1.41	111.02	15.34
22	16.17	82.36	21.33	15.03	3.43	65120.06	11.07	10.08	1.43	111.05	15.26
23	16.41	78.77	20.49	14.98	3.44	65761.60	11.04	11.15	1.43	110.65	15.28
24	15.23	76.67	18.01	14.90	3.46	66986.35	11.40	6.45	1.44	109.29	15.32
25	15.79	84.91	15.39	15.01	3.49	64897.68	11.74	7.31	1.45	111.28	15.30
26	16.15	82.72	16.78	14.96	3.40	66267.76	11.27	10.04	1.41	110.95	15.40
27	15.67	79.63	15.84	14.96	3.41	66986.73	10.84	10.20	1.42	109.53	15.42
28	14.82	82.44	13.41	14.85	3.44	68463.81	10.85	8.92	1.43	108.30	15.44
29	14.81	80.05	13.81	14.82	3.46	69728.71	10.38	10.34	1.44	107.45	15.52
30	14.98	80.77	20.53	14.80	3.55	69424.04	10.57	9.89	1.48	108.51	15.48
31	14.69	79.89	11.86	14.74	3.49	69585.58	10.87	8.92	1.46	108.81	15.44
監測日數	30	30	30	30	30	30	30	30	30	30	30
平均值	15.95	87.14	15.81	15.01	3.32	66768.90	10.75	9.90	1.38	110.12	15.50
最大值	17.74	103.39	30.65	15.27	3.55	69728.71	11.74	14.66	1.48	112.75	15.84
發生日期											
最小值	14.69	76.67	7.97	14.74	2.92	64897.68	9.79	6.45	1.22	107.45	15.26
發生日期											
超標準時數	0	0	0	0	0	0	0	0	0	0	0
標準值	150	220	150	-----	-----	-----	-----	60	20	-----	-----
備註											

廠長

維修組長

操作組長

值班主管